



## COUNTY OF PRINCE WILLIAM

5 County Complex Court, Suite 120, Prince William, Virginia 22192-5308  
(703) 792-6930 Metro 631-1703 Fax: (703) 792-5285

**DEPARTMENT OF  
DEVELOPMENT  
SERVICES**  
Division of  
Building Development

### **BUILDING OFFICIAL INTERPRETATION 2015-01**

**March 09, 2020**

**CODE/EDITION: VIRGINIA UNIFORM STATEWIDE BUILDING CODE/2015**

**SECTION(S): Section 108.0 Application for Permit**

**QUESTION:**

1. Is a Construction Permit required when mechanical equipment (i.e. roof top unit, air handling unit, hot water heater) is being repaired and individual parts of that mechanical equipment must be replaced?
2. Is a Construction Permit required when the entire mechanical unit is being replaced?
3. Is a Construction Permit required when a mechanical fire damper is being replaced with an identical fire damper?

**ANSWER:**

1. No. Based on Section 108.1 When Permit is Required, the replacement of an individual part with the exact same part within an existing mechanical unit is considered an ordinary repair.
2. Yes, if the mechanical equipment is fueled by gas or oil.

No, if the mechanical equipment is not fueled by gas or oil and is in a Use Group R-2 where serving a Single Family Dwelling and Use Group R-3, R-4, and R-5.

Yes, if the mechanical equipment is in any other Use Groups.

3. Yes. If a replacement part is associated with a building's life safety system (i.e. sprinkler system, fire alarm system, smoke evacuation, mechanical fire dampers), then the work is not an ordinary repair, and a permit is required.

Eric M. Mays, P.E.  
Building Official