

COUNTY OF PRINCE WILLIAM

5 County Complex Court, Suite 120, Prince William, Virginia 22192-5308 (703) 792-6930 Metro 631-1703 Fax: (703) 792-5285

DEPARTMENT OF
DEVELOPMENT
SERVICES
Division of
Building Development

BUILDING OFFICIAL INTERPRETATION 2015-07 March 09, 2020

CODE/EDITION: VIRGINIA UNIFORM STATEWIDE BUILDING CODE/2012

SECTION(S): IBC/2015, Section 1010.1 Doors, Gates, Turnstiles

IBC/2015, Section 1010.2 Gates

IBC/2015, Section 1028.5 Access to a Public Way

QUESTION:

- 1. If a fenced in area (i.e. playground; outside storage area; unloading area) serves as part of the exit discharge for a building, is the fence required to have an opening(s) and/or gate(s) installed to prevent obstruction of the Exit Discharge?
- 2. When a fence opening or gate is required to prevent the obstruction of the Exit Discharge, is the fence opening or gate required to comply with Section 1010.1 Doors?

ANSWER:

- 1. Yes, unless the area complies with IBC Section 1028.5 Access to Public Way, Exceptions 1 through 4.
- 2. Yes.

(NOTE: For daycares and schools, if full time supervision is provided, a Code Modification Request may be considered with regard to the requirement to install panic hardware on the fence gate.

Building Official

[May